



**ST. TAMMANY FIRE DISTRICT #8**  
22455 HWY 36 – PO BOX 937, ABITA SPRINGS, LA 70420  
(985) 892-2065 [www.stfd8.com](http://www.stfd8.com)

## ABITA SPRINGS SHORT TERM RENTAL COMPLIANCE INSPECTION REPORT

OWNER \_\_\_\_\_ CONTACT \_\_\_\_\_

MAILING ADDRESS \_\_\_\_\_

INSPECTED ADDRESS \_\_\_\_\_

PHONE # \_\_\_\_\_ ALTERNATIVE PHONE # \_\_\_\_\_

- Smoke and carbon monoxide detectors are present, operable, and maintained in each bedroom.
- Fire Extinguisher, Dry Chemical with a rating of 1-A:10-B:C or greater mounted and clearly visible. Full and pin installed. Date of expiration\_\_\_\_\_.
- Address is clearly marked on the mailbox and/or residence and is clearly visible at the street.
- Means of egress, corridors, hallways, and stairways are free of obstructions.
- Perimeter of building is free of accumulation of weeds, trash, tires, and other debris
- Emergency exitways (doors and windows) are not blocked or secured in a way to prevent the use for exit in an emergency.

**Note any other safety hazards observed at time of inspection**

### COMMENTS:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

This inspection was performed for the purpose short-term rental permitting in the Town of Abita Springs. The inspection shall establish pre-fire planning, hazard identification and mitigation and smoke and carbon monoxide detector compliance.

**Owner** \_\_\_\_\_ **Signature** \_\_\_\_\_ **Date** \_\_\_\_\_  
(Print Name)

**Inspector** \_\_\_\_\_ **Signature** \_\_\_\_\_ **Date** \_\_\_\_\_  
(Print Name)